

ME.C. 3.1

NO.FS/MMT/2020-21/444
GOVERNMENT OF MIZORAM
FIRE & EMERGENCY SERVICES DEPARTMENT
MAMIT FIRE STATION


Dated Mamit the 27th March 2021

NO OBJECTION CERTIFICATE (PROVISIONAL)

District Hospital, Mamit has been inspected on 27.3.2021 in respect of implementation of Fire Prevention arrangement and the undersigned has no objection in its occupation /utilization for the Hospital, subject to the installation of the following Fire fighting arrangements as per the provision of part IV of NBC, 2016 as mentioned below:

1. Static terrace water tank with a capacity of 5000 litres to feed Hose reel.
2. Hose reel hose to be installed at ground floor and first floor.
3. Fire Alarm System (Manual).
4. Fire extinguisher ABC/DCP-4kg/5kg, one (1) no at first floor Operation Theatre room.
5. Fire extinguisher ABC/DCP-4kg/5kg, Five (5) nos at ground floor.

This provisional NOC is valid for 2 (two) years which may be renewed for another 2(two) years on receipt of proper application indicating the reason for its renewal. Final NOC will be issued after satisfactory inspection report about the installation of the above Fire fighting arrangement is received.



(LALNGURTHANGA)
Officer in-charge
Mamit Fire Station
Fire & Emergency Services
Mamit : Mizoram

Memo: NO.FS/MMT/2020-21/444

Dated Mamit the 27th March 2021

Copy to :

1. Director, Fire & Emergency Services for information.
2. Deputy Commissioner, Mamit for information.
3. Guard file.


Officer in-charge
Mamit Fire Station
Fire & Emergency Services
Mamit : Mizoram



OFFICE OF THE MIZORAM STATE POLLUTION CONTROL BOARD
AIZAWL : MIZORAM

RED

CONSENT TO OPERATE

No.H.88088/Poltn/21(10)/09-MPCB/ 335-337 :

Dated Aizawl, the 25th March, 2022
Valid till 25th March, 2027

CONSENT TO OPERATE is hereby renewed under Section 21 of Air (Prevention & Control of Pollution) Act, 1981 as amended and Section 25/26 of Water (Prevention & Control of Pollution) Act, 1974 as amended (to be referred as Air Act and Water Act respectively) to M/S District Hospital, to operate Health Care Facility at Mamit District having an installed bed capacity of 30 Nos with reference to the application no. D.13012/1/09-DMS(M)/683 dated 15.03.2022 & Consent To Operate granted vide letter No. 2(10)/2009-MPCB dt 15.9.2017 and subsequent correspondence under the following terms and conditions: -

A. GENERAL CONDITIONS:

- (1) The applicant shall make an application for renewal of Consent at least 30 days before the date of expiry of this consent.
- (2) The industry would immediately submit the revised application for consent to this Board in the event any change in the raw material, process, pollution control equipments, or increase in production, rate of emission, rate of waste water discharge etc.
- (3) The existing control equipment, if any shall only be altered or replaced in accordance with the directions of the Board.
- (4) A good housekeeping shall be maintained both within the factory and in the premises. All hoods, pipes, valves shall be leak proof.
- (5) An inspection book shall be opened and made available to the Board's Officers during their visit to the factory.
- (6) The applicant shall comply with and carry out directives /order issued by the Board in this Consent Order in addition to that of No Objection Certificate and at all subsequent times without any negligence on his part. The applicant shall be liable for such legal action against him as per provisions of the Law/Act in case of non-compliance of any order/directive issued at any time and/or violation of the terms and conditions of this consent order.
- (7) Where in any Air pollution control area the emission of any air pollutant in to the atmosphere in excess of the standards laid down by the Board occurs or is apprehended to occur due to accident or other unforeseen act or event, the person in charge of the premises from where such emission occurs or is apprehended to occur shall forthwith intimate the fact of such occurrence or the apprehension of such occurrence to this Board, telegraphically under intimation to the District Health Officer.

- (8) In case of such episodic discharges/emissions mentioned above the industry should take immediate action to bring down the emission below the limits prescribed in the No Objection Certificate.
- (9) This consent does not authorize or approve the construction of any physical structure or facilities or the undertaking of any work in any natural watercourse.
- (10) The applicant shall furnish to the visiting officer and /or the Board any information regarding the constructions, installation or operation of the Air Pollution Control equipment system and such other particulars as may be pertinent to prevention and control of pollution of air.
- (11) If due to any technological improvement or otherwise this Board is of opinion that all or any of the conditions referred above requires variation (including the change of any control equipment either in whole or in part), this Board shall after giving the applicant an opportunity of being heard, vary all or any or such conditions and there upon the applicant shall be bound to comply with the conditions so varied.
- (12) This certificate will remain valid for a period of 5(five) years from the date of issue.
- (13) The applicant, however, shall pay an annual consent fee every year before end of failing to comply which, this certificate is liable to be cancelled.
- (14) This Certificate has been accorded basing on the particulars furnished by the applicant on behalf of M/S District hospital, Mamit and subject to addition of further or more conditions if so warranted by subsequent developments. The consent will automatically become invalid if any change or alteration or deviation is made in actual practice


B. SPECIFIC CONDITIONS:

I. WATER:

- a. Effluent Treatment Plant of suitable capacity should at all-time be utilized to treat waste water from the laboratory, OT etc.
- b. Rain water harvesting for roof & surface run-off should be implemented.
- c. The bio- medical liquid waste should not be mixed with the other waste water.


II. AIR:

- a. The industry shall ensure that the ambient noise level should not exceed 55 dB(A) Leq during day time and 45 dB(A) Leq during night time. Day Time starts from 6:00 A.M and extends up to 6:00 P.M and Night time means 6:00 P.M to 6:00 A.M
- b. Machines capable of producing high level of noise shall be installed & operate in an acoustic enclosure only. Ceiling and walls shall be lined with cotton or similar material to absorb noise.
- c. In case Diesel generator is to be used, the guidelines as issued by Central Pollution Control Board must be strictly complied with.



III. WASTE MANAGEMENT:

- a. Any other type of solid waste shall not be mixed with the solid bio- medical wastes. Solid wastes must be properly stored and disposed as per the Solid Waste Management Rules, 2016
- b. Electronic wastes, if any in any case should not be mixed with solid wastes and send to registered recyclers/ dismantlers or collection centre.
- c. Following the Hon'ble National Green Tribunal (NGT)'s order, Open burning of wastes is strictly prohibited by the Govt. of Mizoram vide Notification No.C.18014/37/97/FST/Pt dated 14.6.2018. As per the Notification, each such incident or default, violators responsible for such burning shall be liable to pay environmental compensation of Rs 5000/- (Rupees five thousand) only in case of simple burning and Rs 25,000/- (Rupees twenty five thousand) only in case of bulk waste burning. **The Unit shall comply with the government order in all respect.**
- d. Maintenance of deep burial pit and sharp pit must as per Schedule II of the Bio- Medical Waste Management Rule, 2016 should be strictly complied with.
- e. Microbiology waste and all other clinical laboratory waste shall be pre-treated by sterilization.
- f. Use of chlorinated gloves or plastic material is strictly prohibited.
- g. A Bar-Code System for bags or containers containing bio-medical waste for disposal has to be established.
- h. Separate storage room must be made available for storage of Bio- medical wastes.



Sd/-C.LALDUHAWMA

Member Secretary

Mizoram Pollution Control Board

: Dated Aizawl, the 25th March, 2022

Memo No.H.88088/Poltn/21(10)/09-MPCB/ 335-337

Copy to: The District Medical Superintendent, District Hospital ,Mamit District.

(C.LALDUHAWMA)

Member Secretary

Mizoram Pollution Control Board